




# Z100

## 15 [381] DIAMETER MAIN ROOF DRAIN LOW SILHOUETTE DOME

TAG \_\_\_\_\_

Dimensional Data (inches and [mm]) are Subject to Manufacturing Tolerances and Change Without Notice



A- Pipe Size In.	Approx. Wt. Lbs. [kg]	Dome Open Area Sq. In. [cm <sup>2</sup> ]
2-3-4 [51-76-102]	26 [12]	103 [665]
5-6 [127-152]	27 [12]	
8 [203]	28 [13]	

**ENGINEERING SPECIFICATION: ZURN Z100**  
15 [381] Diameter roof drain. Dura-Coated cast iron body with combination membrane flashing clamp/gravel guard and low silhouette Poly-Dome.

**OPTIONS** (Check/specify appropriate options)

**PIPE SIZE**

- 2 thru 6-8 [51 thru 152-203]
- 2 thru 6-8 [51 thru 152-203]
- 2 thru 6-8 [51 thru 152-203]
- 2-3-4 [51-76-102]

(Specify size/type) **OUTLET**

- \_\_\_\_\_ IC Inside Caulk
- \_\_\_\_\_ IP Threaded
- \_\_\_\_\_ NH No-Hub
- \_\_\_\_\_ NL Neo-Loc

**E BODY HT. DIM.**

- 5 1/4 [133]
- 3 3/4 [95]
- 5 1/4 [133]
- 4 5/8 [117]

**PREFIXES**

- \_\_\_\_\_ Z D.C.C.I. Body with Poly-Dome\*
- \_\_\_\_\_ ZA D.C.C.I. Body with 6 3/4 [171] High Aluminum Dome
- \_\_\_\_\_ ZC D.C.C.I. Body with Cast Iron Dome
- \_\_\_\_\_ ZRB D.C.C.I. Body with Plain Bronze Dome

**SUFFIXES**

- |   |  |
|---|--|
| _____ -AC Angular Underdeck Clamp   | _____ -HD 6 3/4 [171] High Aluminum Dome Strainer (148 Sq. In. [955 cm <sup>2</sup> ] Open Area) |
| _____ -AR Acid Resistant Epoxy Coated   | _____ -R Roof Sump Receiver  |
| _____ -AW 3/4 [19] to 4 [102] Adj. Water Level Regulator                                  | _____ -SC Secondary Clamping Collar  |
| _____ -BS Bronze Mesh Screen Over Dome  | _____ -SS Stainless Steel Mesh Screen Over Dome  |
| _____ -C Underdeck Clamp  | _____ -TC Neo-Loc Test Cap Gasket (2 - 4 [51 - 102] NL Bottom Outlet Only)                       |
| _____ -DP Top-Set® Deck Plate (Replaces both the -C and -R)                               | _____ -VP Vandal-Proof Secured Top   |
| _____ -DR Top-Set® Drain Riser  | _____ -W2 2 [51] Internal Water Dam  |
| _____ -DX Dex-o-tex Flange  | _____ -W3 3 [76] Internal Water Dam  |
| _____ -E Static Extension 1 [25] thru 4 [102] (Specify Ht.)                               | _____ -W4 4 [102] Internal Water Dam   |
| _____ -EA Adjustable Extension Assembly 1 3/4 [44] thru 3 1/2 [89]                        | _____ -XJ Vertical Expansion Joint (See Z190)  |
| _____ -EB Top-Set® Adjustable Extension Assembly  | _____ -84 Stainless Steel Perforated Gravel Guard  |
| _____ -ES Static Extension with Secondary Clamp at Body (for clamping at roof drain body) | _____ -85 Stainless Steel Perforated Extension   |
| _____ -FG Flush Grate (Replaces Dome Strainer)  | _____ -89 2 [51] High External Water Dam   |
| _____ -FS Flat Strainer (ZB or ZN)  | _____ -90 90° Threaded Side Outlet Body (2 thru 6 [51 or 152])                                   |
| _____ -G Galvanized Cast Iron   |  |
| _____ -GD Galvanized Cast Iron Dome (ZC Only)   |  |

\*REGULARLY FURNISHED UNLESS OTHERWISE SPECIFIED

<b>REV. I</b>	<b>DATE: 5/9/05</b>	<b>C.N. NO. 93332</b>
<b>DWG. NO. 59285</b>	<b>PRODUCT NO. Z100</b>	